

FIRE STOPPING

BY NORSEAL

FIRE PILLOW

FSI



Application

Designed for multi-service penetrations in rigid walls and floors, where services are being continuously changed or replaced

Fixing

Positioned in aperture

Performance

Fire tested to BS 476 & EN 1366-4

Acoustically tested in accordance with EN 10140-2

Air Permeability tested to EN 1026

Certifire CF514

Electrical Installations Fire tested to BS 7671-42:52

Material

Organic fillers & intumescent additives within a waterproof glass cloth bag

Colours

Silver (S)

Sizes (mm)

330x50x20 (S100), 330x200x25 (S250), 330x200x45 (S800)

Order code

Size + /Colour eg. S100/S (330x50x20mm, Silver)

 5 Regents Drive
Prudhoe
Northumberland
NE42 6PX

 norseal.co.uk

 firestopping@norseal.co.uk

 01661 520 930

Registered at Companies House Cardiff No. 04317595 VAT Reg. No. 733 9466 08